

GOVT. SR. SEC. SCHOOL JATTAL (2136) (PANIPAT)

Ref. No 4106

Dated 26-6-24

सेवामें,

जिला परियोजना समन्वयक
पानीपत ।

विषय :- CBSE में पंजीकरण के सन्दर्भ में मार्गदर्शन
बारे ।

उपरोक्त सन्दर्भ में सूचित किया जाता है कि
विद्यालय के ऊपर से हायर एक्सटेंशन वायर गुजरती
है जिसके कारण अग्निशमन विभाग ने कायर अप्रुवल
प्रमाण पत्र देने से मना करते हुए लिखा है कि पहले
तारे हटवाई जाए इसके उपरान्त ही अप्रुवल दी जा
सकेगी । विद्यालय की ओर से KYC करवाकर CBSE
हेतु आवेदन का प्रयास किया लेकिन प्रमाण-पत्र के अभाव
में करना संभव नहीं है । इस सन्दर्भ में पहले भी
सूचित किया गया था । अतः आपसे निवेदन है
कि उक्त सन्दर्भ में विद्यालय का मार्गदर्शन करने
का कष्ट करें ।

संलग्न - पत्र अग्निशमन कार्यालय


PRINCIPAL
PM Smt GSSS Jattal
Panipat (2136)

o/c

School Code (Dept.) : 2136
School Code (Board) : 14061

E- mail Id:- gsssjiattalpanipat@gmail.com
Phone no. :- 9416866378



**PM SHRI
GOVERNMENT SENIOR SECONDARY SCHOOL
JATTAL (PANIPAT)**

Ref. No. : H.O.10.....

Date: 18/03/2024

To:
D P C
Panipat.


Subject— REGARDING APPROVAL OF FIRE
SAFETY CERTIFICATION.

In reference to our School,s online
Application no.140842423000091 dated 24/02/2024
regarding Approval on the subject cited above ,The
Fire Station Officer, Panipat has pointed out an
observation of the Higher Tension Line pass above
our School Building and advised us to rectify this
Observation at the earliest.

The Observation Letter of FSO Panipat is
forwarded to you for information and further
necessary action.

Attached : The Letter of FSO.

Meen
18/03/2024


PRINCIPAL
PM Shri GSSS Jattal
Panipat (2136)

Fire & Emergency Services Haryana

Fire Station Office Hali Park Panipat

Tel. 0180-2650458, 112

Email- hfs.panipat@gmail.com

Fire Station Officer,
Panipat

PM Sbi GSSS Jattal,
Village Jattal, Panipat

Memo No. HFS/PNP/2024/ 224

Dated: 2/2/24


Subject: Observation Letter.

In reference of your online application no. 140842423000091 dated 24/02/2024 on the subject cited above.

Online applications has been checked and found that some observation pointed out under as follows: -

1. High-tension line pass over on your school building.

You are request to rectify observation at the earliest and afterwards reach to this office for approval of Fire Safety Certificate.


Fire Station Officer,
Panipat